



# EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert NO. GYJ111330

This is to certify that the product

Isolated Safety Barrier

manufactured by

Measurement Technology Limited

(Address: Great Marlings, Butterfield, Luton, Bedfordshire, LU2 8DL, UK)

which model is

MTL5511、MTL5514、MTL5516C、MTL5517

Ex marking

[Ex ia] II C

product standard

/

drawing number

/

has been inspected and certified by NEPSI, and that it conforms

to

GB3836.1 - 2000、GB3836.4 - 2000

This Approval shall remain in force until 2016.06.22

Remarks

1. Special conditions for safe use specified in the attachment to this certificate.
2. Intrinsic safe parameters: see the attachment to this certificate.

Director

National Supervision and Inspection Centre for  
Explosion Protection and Safety of Instrumentation

Issued Date 2011.06.23



This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road  
Shanghai 200233, China

<http://www.nepsi.org.cn>  
Email: [info@nepsi.org.cn](mailto:info@nepsi.org.cn)

Tel:0086 21 64368180  
Fax:0086 21 64844580